


US EPA ARCHIVE DOCUMENT



Hawaii WWTP Energy Audits

“A Virtual Tour”

February, 2010

Today's Agenda

- The energy audit process
- 4 plants 4 stories
- WWTP “Virtual Tour”
- Energy audit do's and don'ts
- Conclusions





Benefits of Energy Audit?

- Improve understanding of processes
- Bridge energy use and accounting
- Gain comprehension of utility bills
- Clarity of energy use and effects
- Improve resource utilization
- Enhance relationship with utility provider
- Improve relationship with rate payers

Benefits of Energy Audit?

- Recognize your successes
- Goal development
- Reduce operating costs
- Prepare for a renewable future
- Three legged stool: energy efficiency, energy conservation and renewable energy generation



PLANT

UTILITY ACCOUNTING

Energy Audit - Road Map






START

**AUDIT TYPE
AND LEVEL**

AUDIT TEAM

**INFORMATION
COLLECTED**

ON-SITE AUDIT




FINISH

**CONTINUOUS
MONITORING**

IMPLEMENT

**ECO DEVELOPMENT
AND FUNDING**



Audit Sequence – Define Audit Type


- Many types of energy audits
 - Equipment audit
(i.e. pumps, compressed air, lighting)
 - Process audit
(i.e. aeration, hydraulic capacity, or overall treatment process)

Audit Sequence – Define Level of Audit

- Three basic levels
 - **LEVEL I:** preliminary energy use evaluation, identify low-cost/no-cost measures, identify potential capital improvements that merit further analysis
 - **LEVEL II:** more detailed facility survey and energy analysis, develop energy use breakdown, identify practical improvements that meet owners constraints and economic criteria
 - **LEVEL III:** detailed analysis of capital-intensive modifications, requires more field data and engineering analysis, detailed cost and savings information developed for decision making

Audit Sequence – Pre Audit Info Gathering

- Site plan
- All utility bills
- Utility schedules
- Process flow diagram
- Electric diagrams
- Detailed equipment list with installation dates
- Pre site visit analysis



Audit Sequence – Utility Bill Analysis

- Local rate schedules
- Reconcile energy use
- Create baseline
- Develop energy accounting assumptions
- Minimum 2 yrs of analysis
- Determine demand sensitive operations

Select the RIGHT TREE and plant it in the RIGHT PLACE to eliminate potential electrical safety hazards.

ACCOUNT NUMBER SERVICE ADDRESS PAGE 1 OF 2

11/13/09 BALANCE FROM PREVIOUS BILLING \$81,457.12
PAYMENT - THANK YOU 81,457.12
BALANCE PRIOR TO BILLING 40.00
CURRENT ELECTRIC SERVICE DUE 12/19/09 76,053.16
TOTAL AMOUNT DUE \$76,053.16

AMOUNTS

P3 LARGE POWER DP	CUSTOMER CHARGE	\$225.00
FROM 10/27/09 TO 11/25/09 29 DAYS	DEMAND CHARGE	5,604.80
MTR	ENERGY CHARGE	31,374.56
CURRENT READING KILOWATT HOURS 22398	POWER FACTOR (.99)	519.74-
PREVIOUS READING 22851	2.0 DP DIET FRI	789.61-
DIFFERENCE 553	CAPACITY SURCHARGE	0.55-
MULTIPLIER 2400	RIDER DISCOUNT	284.01-
USAGE 137,300	INTERIM RATE INCREASE	2,612.81
DEMAND READING KILOWATTS 289	FEF SURCHARGE	321.99
MULTIPLIER 2400	ENERGY COST ADJUSTMENT	17,373.82
MEASURED DEMAND 693.6	BILLING DEMAND	669.6
	TOTAL FOR SERVICE	\$76,053.16

BILL DETAILED

USAGE PROFILE


DATE	KWH	AMOUNT	DAYS	KWH/DAY	\$/DAY
11/25/09	31900	\$76,053.16	29	11,000.0	2,622.52
12/01/09	31900	76,053.16	29	11,000.0	2,622.52
12/07/09	31900	76,053.16	29	11,000.0	2,622.52
12/13/09	31900	76,053.16	29	11,000.0	2,622.52
12/19/09	31900	76,053.16	29	11,000.0	2,622.52

WHEN PAYING IN PERSON, PLEASE PRESENT BOTH PORTIONS
PLEASE DETACH AND RETURN THIS PORTION WITH YOUR PAYMENT

ACCOUNT NUMBER TOTAL AMOUNT DUE \$76,053.16
DATE DUE DEC 19, 2009 AMOUNT ENCLOSED
PLEASE MAKE CHECKS PAYABLE TO:

Audit Sequence – Electric Demand Sensitivity


- Demand can be 15-40% of your elec. costs



Audit Sequence – Demand Sensitivity Cont...


- Determining your demand spikes can save \$
- 300kW over typical peak demand = \$50k/yr

WWTP Electric Demand – 30 Minute Interval Data



Audit Sequence – Energy Cost Adjustment


- This factor is somewhat unique to Hawaii
- This factor is added to energy use (kWh)



Audit Sequence – Baseline & Benchmark

- Goal development – where are you?
- Your personal “Benchmark”
- Framework for strategic planning
- Benchmark analysis allows industry comparison on a “macro level”
- Factor in local considerations
- Benchmark comparison options include: self, regional, national, etc...


Audit Sequence – What Energy Balance?



Audit Sequence – Energy Balance Part 1

- Draw boundary (BOX) around plant
- Determine all materials and energy entering and exiting the BOX
 - Influent flow into and through plant
 - Energy and fuel into plant
 - Potable water into plant
 - Effluent flow out of plant
 - Solids out of plant
 - Self-generated energy out of plant



Audit Sequence – Your Energy Balance!




Audit Sequence – Energy Balance Part 2

- Develop baseline metrics (e.g. MMBTU_{eq} per MG)
- Analyze energy use for each process type

PLANT #1



PLANT #2



Energy Analysis – ECO Development

- What's an ECO?
- ECO = Energy Conservation Opportunity
- Ask the “Investigative” questions
 - “Why are blowers operating 24/7?”
 - “Why are UV and chlorine disinfection required prior to discharge?”
 - “How efficient is a constant pressure pumping system with variable demands?”
 - “How often does sludge dewatering occur?”




Energy Analysis – Example ECOs


- High efficiency motors
- Variable operation motors and drives
- Process optimization
- Process replacement
- Schedule modifications
- Water reuse



The Hawaii Story



Four Plants.... Four Stories



Hawaii - *Four Plants, Four Stories*

- Kailua WWTP, Oahu
 - 13 MGD / Fixed film
 - Influent & effluent pumping
 - Comprehensive odor control
 - UV disinfection
 - Anaerobic digestion


- Waimea, Kauai
 - 0.25 MGD / Aeration basins
 - Influent & effluent pumping
 - New treatment plant coming soon
 - Effluent reuse

- Kihei, Maui
 - 3.5 MGD / Aeration Basins
 - Reclaim water & effluent pumping
 - UV disinfection
 - Effluent reuse

- Hilo, Hawaii
 - 2.5 MGD/ Fixed film
 - NO influent & effluent pumping
 - Anaerobic digestion


WWTP Flow Diagram - Kihei

Conventional Activated Sludge Plant




WWTP Flow Diagram - Waimea

Conventional Activated Sludge Plant




WWTP Flow Diagram - Kailua



Fixed Film Plant

WWTP Flow Diagram - Hilo




Fixed Film Plant

WWTP – Energy Audit Evaluation Areas

Process Systems:

- Hydraulic Capacity
- Aeration
- Pumping
- Disinfection
- Biosolids




Non-Process:

- Buildings
 - Roofs
 - Walls
 - Lighting
 - HVAC
 - Space Utilization
- Property
 - Landscape
 - Site Design
- Vehicle Options

Both:

- | | | | |
|---------------|--------------|------------------|--------------------|
| • Maintenance | • Security | • Behavioral | • Renewable Energy |
| • Reliability | • Automation | • Site Utilities | • Procurement |

WWTP Virtual Tour 1 of 10 – Site Layout



- Multiple buildings
- Multiple process systems
- Different operating schedules
- Property limitations
- Odor control issues

Kailua WWTP Site Layout

Virtual Tour 2 of 10 – Influent Pumping

- Gravity fed or pumped flow
- Flow control



Virtual Tour 3 of 10 – Pre Treatment

- Screening and solids removal equipment
- Odor control



Virtual Tour 4 of 10 – Primary Treatment

- Primary sedimentation tanks
- Wastewater and sludge pumping



Hilo WWTP Primary Sedimentation Tanks

Virtual Tour 5 of 10 – Secondary Treatment

- Fixed film or conventional activate sludge?



Hilo WWTP
Biotowers & Pumps





Kihei WWTP Aeration Basins



Virtual Tour 6 of 10 – Sludge Treatment

- Methods - digestion, composting and incineration
- Typically depends on amount of solids generated




Virtual Tour 7 of 10 – Solids Dewatering

- Required to make sludge suitable for disposal
- No process exists to eliminate need for biosolids disposal



Hilo, Kailua & Kihei WWTP
Centrifuging



Waimea WWTP
Solar Drying

Virtual Tour 8 of 10 – Disinfection

- Methods – ozone, chlorine and ultraviolet (UV) light





Hilo & Waimea WWTP
Chlorination




Kailua & Kihei WWTP
Ultraviolet Light

Virtual Tour 9 of 10 – Effluent Pumping

- Gravity fed or pumped flow
- Flow control
- Water reuse – 2 of 4 WWTP



Virtual Tour 9 of 10 – Effluent Pumping Cont...



Virtual Tour 9 of 10 – Effluent Pumping Cont...



Virtual Tour 10 of 10 – Auxiliary Systems



Compressed Air



Odor Control



City Water & Site Booster



Controls & Auto.



Aeration
Blowers



Lighting

Four Stories - Four Unique Circumstances

Considerations associated with auditing infrastructure facilities:


- Every facility is unique with ever-changing and uncontrollable parameters
- Plants have specific process requirements
- Site specific permits, restrictions, regulations and rate structures
- Each plant is located in a unique setting providing potential opportunities and specific issues to overcome

Comparing “Treatment Plant Unique DNA”


PROCESS	HILO	KAILUA	KIHEI	WAIMEA
<i>Influent Pumping</i>				
<i>Screening/Grit Removal</i>				
<i>Primary Sedimentation</i>				
<i>Fixed Film (Biotower)</i>				
<i>Aeration Basins</i>				
<i>Secondary</i>				
<i>Solids Contact</i>				
<i>Advanced Water Treatment</i>				
<i>Chlorine Disinfection</i>				
<i>Ultraviolet</i>				
<i>Effluent Pumping</i>				
<i>Common Outfall Pumping</i>				
<i>Comprehensive Odor Control</i>				
<i>Thickening</i>				
<i>Aerobic Digestion</i>				
<i>Anaerobic Digestion</i>				
<i>Digester Gas Utilization-Heating</i>				
<i>Digester Gas-Cogeneration</i>				
<i>Dewatering-Centrifuge</i>				
<i>Dewatering-Solar Drying</i>				
<i>Landfill</i>				
<i>Composting</i>				
<i>Water Reuse</i>				
<i>FOG Program</i>				

Resource Cost Breakdown

Hilo WWTP = \$650,000/yr




Kailua WWTP = \$1,700,000/yr




- Electric
- Water
- Propane
- Fuel Oil

Kihei WWTP = \$1,000,000/yr



Waimea WWTP = \$100,000/yr



Hilo WWTP Electrical Energy Breakdown

Electrical Energy User / Equipment Description	Est. Electric Energy Use (kWh/yr)	Est. Electric Energy Cost (\$/yr)	Est. Electric Energy Use/ Cost (%)
Biotower Pumps	663,000	\$209,000	33%
Primary Aeration Blowers	431,000	\$136,000	22%
No. 3 Water Pumps	226,000	\$71,000	11%
Digester Sludge Mix Pumps	184,500	\$58,000	9%
Secondary Aeration Blowers	74,500	\$23,000	4%
Solids Processing Odor Ctrl Fan	76,000	\$24,000	4%
No. 2 Water Pumps	51,000	\$16,000	3%
Grit Pumps	65,500	\$21,000	3%
Primary Odor Control Fans	41,500	\$13,000	2%
Primary Sludge Pumps	48,500	\$15,000	2%
Balance of Plant	37,000	\$12,000	2%
Admin/Maint Building Load	37,000	\$12,000	2%
Centrifuges	18,500	\$6,000	1%
Lighting Load	17,500	\$6,000	1%
DAF Thickened Sludge Pumps	4,700	\$1,000	0.2%
Digester Sludge Transfer	3,800	\$1,000	0.2%
Est. Annual Electric Use	1,980,000	\$624,000	100%

Kailua WWTP Electrical Energy Breakdown

Electrical Energy User / Equipment Description	Est. Electric Energy Use (kWh/yr)	Est. Electric Energy Cost (\$/yr)	Est. Electric Energy Use/ Cost (%)
Effluent Pumps	2,189,000	\$442,910	28%
Biotower Pumps	1,314,000	\$265,867	17%
Influent Pumps	1,139,000	\$230,459	14%
Secondary Odor Ctrl Fan	657,000	\$132,934	8%
Secondary Aeration Blowers	526,000	\$106,428	7%
DAF Sludge Pressurization Pumps	526,000	\$106,428	7%
Primary Odor Ctrl Fan	438,000	\$88,622	6%
Digester Sludge Pumps	350,000	\$70,817	4%
Return Activated Sludge Pumps	228,000	\$46,132	3%
Admin/Maint Building Load	174,000	\$35,206	2%
Centrifuges	96,000	\$19,424	1%
Solids Processing Odor Ctrl Fan	48,000	\$9,712	1%
Digester Grinders	71,000	\$14,366	1%
Centrifuge Sludge Pumps	38,000	\$7,689	0.5%
Primary Sludge Pumps	39,000	\$7,891	0.5%
Primary Effluent Pumps	22,000	\$4,451	0.3%
Waste Activated Sludge Pumps	13,000	\$2,630	0.2%
Sludge Thickener Pumps	15,000	\$3,035	0.2%
DAF Pocket Pumps	15,000	\$3,035	0.2%
Primary Grit Pumps	11,000	\$2,226	0.1%
Primary Scum Pumps	11,000	\$2,226	0.1%
Est. Annual Electric Use	7,920,000	\$1,602,489	100%

Kiehi WWTP Electrical Energy Breakdown


Electrical Energy User / Equipment Description	Est. Electric Energy Use (kWh/yr)	Est. Electric Energy Cost (\$/yr)	Est. Electric Energy Use/ Cost (%)
Primary Aeration Blowers	1,707,900	\$368,231	39%
Effluent Pumps	867,000	\$186,929	20%
Aerobic Digester Agitation Blowers	263,000	\$56,704	6%
Sand Filter Sump Pumps	263,000	\$56,704	6%
Plant Air Compressors	270,500	\$58,321	6%
Admin/Maint Building Load	31,500	\$6,792	1%
Clarifier #1 & #2 RAS Pumps	158,000	\$34,065	4%
Influent Odor Control Fan	118,000	\$25,441	3%
Filter Compressor Station	118,000	\$25,441	3%
Reclaim Transfer Pumps	118,000	\$25,441	3%
Balance of Plant	144,500	\$31,155	3%
Centrifuges	79,000	\$17,033	2%
UV Disinfection System	80,000	\$17,248	2%
WAS Pumps #1 - #5	40,500	\$8,732	1%
Anoxic Mixing Aeration Blowers	22,500	\$4,851	1%
Plant Utility Water Pumps	54,000	\$11,643	1%
Lighting Load	42,000	\$9,055	1%
Digested Sludge Pumps	7,000	\$1,509	0.2%
Est. Annual Electric Use	4,384,400	\$945,296	100%

Waimea WWTP Electrical Energy Breakdown


Electrical Energy User / Equipment Description	Est. Electric Energy Use (kWh/yr)	Est. Electric Energy Cost (\$/yr)	Est. Electric Energy Use/ Cost (%)
Primary Aeration Blowers	202,100	\$58,674	65%
Effluent Pumps	46,340	\$13,454	15%
Influent Pumps	21,800	\$6,329	7%
Balance of Plant	17,520	\$5,086	6%
Admin/Maint Building Load	13,100	\$3,803	4%
Lighting Load	11,300	\$3,281	4%
Sludge Drying Bed Underdrain Pumps	430	\$125	0.1%
Est. Annual Electric Use	312,590	\$90,752	100%

WWTP Electrical Energy Breakdowns


Hilo WWTP
1,980,000 kWh/yr




Kailua WWTP
7,920,000 kWh/yr







Kihei WWTP
4,384,000 kWh/yr



Waimea WWTP
313,000 kWh/yr



Current Plant Energy Baselines




ECO #1 – Hilo Electric Demand Management

Hilo's Current Electrical Demands

- 15% of site electric costs = >\$82k/year*


Bill Period	Measured Peak Demand (kW)	Billed Peak Demand (kW)
Jul-08	276	282
Aug-08	270	279
Sep-08	264	276
Oct-08	258	273
Nov-08	270	279
Dec-08	264	276
Jan-09	276	282
Feb-09	252	270
Mar-09	258	267
Apr-09	256	267
May-09	264	270
Jun-09	252	264
AVERAGE	263	274



* Based on 2009 data collected from January 2009 – June 2009

Hilo WWTP – Electrical Demand Trend

Hilo WWTP Monthly Electric Demand - 15 Minute Interval Data
January 2009



ECO #1 – Hilo WWTP Recommendation


Electrical Demand Management

- Meter site demand
- Monitoring load data
- Determine spike loads
- Eliminate infrequent spike loads:
26 kW = \$6,700/year
- Reduce regular spike loads:
50 kW = \$12,800/year



ECO #2 – Kihei Aeration Blower & UV Retrofit

- What a difference a year makes!
- Install new Turblex blower & UV system
- Estimated demand savings ~100 kW
- Estimated electrical savings ~1,000 MWh/yr



ECO #3 – Kailua UV Disinfection

- Currently off-line pending re-design
- Energy estimates at 15 MGD flow:
 - Old UV ~250 kW
 - New UV additional ~75 kW
- Payback < 2-3 years
- More efficient = less lamps to do the same job!



Preliminary ECO Results – Hilo WWTP

ECO No.	Recommendation	Potential Energy Reduction (kWh/yr)	Potential Demand Reduction (kW)	Potential Water Reduction (Gal/yr)	Potential Cost Savings (\$/yr)	Estimated Implem. Cost (\$)	Simple Payback (Years)
No-Cost Measures							
1	Operate Dewatering Odor Control Fan Only During Dewatering Periods	69,850	0	0	\$19,100	\$0	0.0
Low-Cost Measures							
2	Eliminate 1 Of 3 Primary Tanks In Use And Optimize Primary Sludge Pump Operations	39,900	14	0	\$11,200	\$5,000	0.4
Investment Grade Measures							
3	Electrical Demand Management	0	26	0	\$6,600	\$50,000	7.6
4	No. 2 Water Pumping System Improvements	35,000	0	6,500,000	\$35,700	\$100,000	2.8
5	Replace Lower Efficiency Motors With Higher Efficiency Motors	136,400	27	0	\$44,300	\$175,000	4.0
6	No. 3 Water Pumping System Improvements	94,800	10	0	\$28,600	\$220,000	7.7
Total Potential Electrical Energy Savings		375,950 kWh/yr					
Total Potential Electrical Demand Savings			77 kW				
Total Potential Water Savings				6,500,000 Gal/yr			
Total Potential Cost Savings					\$145,400 \$/yr		
Total Estimated Implementation Cost						\$550,000	
Total Simple Payback							3.8


Preliminary ECO Results – Kailua WWTP

ECO No.	Recommendation	Potential Energy Reduction (kWh/yr)	Potential Demand ¹ Reduction (kW)	Potential Water Reduction (Gal/yr)	Potential Cost Savings (\$/yr)	Estimated Implem. Cost (\$)	Simple Payback (Years)
Investment Grade Measures							
1	Electrical Demand Management	0	100-350 (738) ²	0	\$115,800	\$75,000	0.6
2	Lighting System Improvements	122,100	25	0	\$24,700	\$154,000	6.2
3	Disinfection System Upgrades	438,000	50	0	\$88,500	\$500,000	5.6
4	Cogeneration	4,000,000	500	0	\$658,000	\$3,750,000	5.7
Total Potential Electrical Energy Savings		4,560,100 kWh/yr					
Total Potential Electrical Demand Savings			675-925 kW				
Total Potential Water Savings				0 Gal/yr			
Total Potential Cost Savings					\$887,000 \$/yr		
Total Estimated Implementation Cost						\$4,479,000	
Total Simple Payback							5.0

Preliminary ECO Results – Kihei WWTP

ECO No.	Recommendation	Potential Energy Reduction (kWh/yr)	Potential Demand ¹ Reduction (kW)	Potential Water Reduction (Gal/yr)	Potential Cost Savings (\$/yr)	Estimated Implem. Cost (\$)	Simple Payback (Years)
Investment Grade Measures							
1	Effluent Water Management	26,000	10	0	\$7,000	\$25,000	3.6
2	Lighting System Improvements	22,700	4	0	\$5,000	\$43,000	8.6
3	Compressed Air System Improvements	105,700	6	0	\$20,500	\$130,000	6.3
Total Potential Electrical Energy Savings		154,400 kWh/yr					
Total Potential Electrical Demand Savings			20 kW				
Total Potential Water Savings				0 Gal/yr			
Total Potential Cost Savings					\$32,500 \$/yr		
Total Estimated Implementation Cost						\$198,000	
Total Simple Payback							6.1

Projected Baselines w/ ECO Implementation



Emerging Stories! Digester Gas Use!



- Kailua and Hilo equipped with anaerobic digesters
- Both use digester gas for digester heating
- Excess gas is burned (Flare stack)
- Cogeneration study for Kailua (2004) indicated 600 KW cogen system possible with 13 MGD flow
- Cogeneration study is being updated, expected in 2010

Emerging Stories! Digester Gas Use!

- General rule of “thumb”
1 MGD ~30 KW cogen
- Options to make more digester gas:
 - Enhance digestion
 - Fat, oil & grease (FOG) addition
 - Other bio-waste



Emerging Stories! FOG

- High heating value (BTU)
- Excellent fuel source
- Disposal down the drain results in collection system blockages & headaches
- FOG recovery and reuse programs being developed throughout the world
- Keeps FOG out of landfills
- Could result in revenue source for agency

RENEWABLES! Location.. Location


- Solar
 - Waimea WWTP
- Wind
- Geothermal (deep well)
- Bio-mass (digesters)
- Hydropower (micro-turbines)



Waimea Solar PV System

- Proposed design:


- 137.7kW DC
- 112.9kW AC
- Polycrystalline type
- 612 REC AE-US 225W DC modules at fixed tilt (www.recgroup.com/usa)
- Size of approximately 11,000ft²



Waimea Solar PV System Cont...

- PV system cost
 - \$799,194
- Est. energy impact
 - 203,077kWh/year
 - 65% of current electric use
 - \$58,892/year*
- 13.5year* SPB

Average Daily Power Production Curve by Month
Waimea - 138 kW DC



* \$0.29/kWh and does not include rate schedule impacts or escalation over time

Energy Audit – Do's and Don'ts

- Three key's to effective auditing:
“Information, *information*, & information!”
- Enlist team concept with plant personnel actively engaged in auditing
- Look beyond the numbers
- Understand local requirements and prohibitions

Energy Audit – Do's and Don'ts Continued...

- Confirm assumptions
- Evaluate “aggressively” but “keep it real”
- Make the auditing process a learning experience for *all participants*

Conclusions!

Good information + Right audit team

=

Enhanced energy utilization +
Increased operational understanding + \$\$\$

- Learn from the experience
- Better resource utilization awareness
- Energy / resource management improvements

MAHALO!

